



# DUCT ACCESS DOOR Model KCD (No Hinge)

DATE



**KARP ASSOCIATES, INC.**  
260 Spagnoli Road Melville, NY 11747  
(631) 768-8300 - Phone  
(631) 768-8350 - Fax

## SPECIFICATIONS

### GENERAL SCOPE:

Access doors shall be Karp Type KHD (Hinged) and Type KCD (No Hinge) as manufactured by Karp Associates, Inc., Melville, N.Y.

Sizes shall be as indicated on the drawings.

### CONSTRUCTION:

1. a. On door sizes of 12 x 12 inches and smaller, door shall be 24 gage galvanized steel.
- b. On door sizes of 14 x 14 inches and larger, door shall be 22 gage galvanized steel.
2. Frame shall be 22 gage galvanized steel.
3. Removable with double cam latches.
4. Door shall be filled with 2" thick fiberglass insulation compressed into 1". R factor = 7.7
5. Gasketing between door and frame shall be 1/2" thick by 1/8" wide closed cell neoprene gasketing.
6. Cam latches shall be zinc plated steel - self-tightening and hand operated.
7. Back of frame to have 5/8" notched knock-over edges.



### STANDARD SIZES

DOOR SIZE H X W (INCHES)	ACTUAL DOOR MEASUREMENTS (INCHES)	DUCT OPENING (INCHES)	CAMS	SHIP WT. (LBS.)
6 x 6	5 1/2 x 5 1/2	4 3/4 x 4 3/4	2	1.1
8 x 8	7 1/2 x 7 1/2	6 3/4 x 6 3/4	2	1.8
10 x 10	9 1/2 x 9 1/2	8 3/4 x 8 3/4	2	2.4
12 x 12	11 1/2 x 11 1/2	10 3/4 x 10 3/4	2	3.2
14 x 14	13 1/2 x 13 1/2	12 3/4 x 12 3/4	4	4.9
16 x 16	15 1/2 x 15 1/2	14 3/4 x 14 3/4	4	5.5
18 x 18	17 1/2 x 17 1/2	16 3/4 x 16 3/4	4	6.6
24 x 24	23 1/2 x 23 1/2	22 3/4 x 22 3/4	4	11.0

PROJECT DATA	
Project Name:	
Architect:	
Contractor:	
Agent/Customer Name:	
Tagging Instructions:	
Special Instructions:	
To be purchased from Industrial Hardware & Specialties, Inc.	
www.industrialhardware.com	
T:973-684-4010 Fax:973-684-3095	



PROJECT SCHEDULE					
Qty.	H	W	No. of Latches	Finish	Remarks



Made with Union Labor

SECTION A-A